

A1



DRAWING STATUS:

SHD - STAGE 3

1. DRAWING TO BE READ IN CONJUNCTION WITH ALL OTHER DRAWINGS AND DOCUMENTATION.
2. THIS DRAWING IS IN PART SCHEMATIC AND THE DOES NOT INDICATE ALL BENDS, CROSS-OVERS ETC TO INSTALL THE SERVICES.
3. ALL EXISTING SERVICES WILL BE RELOCATED AS NECESSARY WITHIN THE SITE BOUNDARY TO INCLUDE MANHOLES, SITE LIGHT LIGHTING ETC.
4. POSITIONING AND EXACT REQUIREMENTS OF BOTH PEDESTRIAN CROSSINGS & PUBLIC LIGHTING DESIGNS WILL BE CONFIRMED WITH LOCAL COUNTY COUNCIL PRIOR TO INSTALLATION.

PRIOR T

- LEGEND:**
- | | |
|-------|---|
| COMMS | COMMS & TV SERVICE PROVIDER
2 x 110mm uPVC DUCTING |
| ESB | NEW ESB
2 x 125mm RED uPVC DUCTING |
| LV | ELECTRICAL SITE SERVICES - 110mm
uPVC DUCTING |
| ESB | EXISTING ESB OVERHEAD LINES |
| ESB | EXISTING ESB UNDERGROUND
SERVICES |
| ESB | PROPOSED DIVERSION ROUTES - NEW
125mm RED uPVC DUCTING |
| ESB | PROPOSED DIVERSION ROUTES - NEW
ESB OVERHEAD LINES |

- | | |
|---|---|
|  | GAS SHUT OFF VALVE |
|  | BORD GAIS GAS METER |
|  | 900mm LONG X 450mm WIDE x
900mm DEEP PRE-CAST CONCRETE
MANHOLE WITH LOCKABLE CAST
IRON LID |
|  | EIRCOM JB4 MANHOLE |
|  | IN-GROUND WEATHERPROOF
JUNCTION BOX (SEE DETAIL) |
|  | LED STREET LIGHT FITTING C/W 6.0
METRE HINGED TUBULAR
STEEL COLUMN |
|  | LED POST TOP LIGHT FITTING C/W
4.0 METRE TUBULAR STEEL COLUMN |
|  | LED POST TOP LIGHT FITTING C/W
5.0 METRE TUBULAR STEEL COLUMN |
|  | LOCAL COUNTY COUNCIL PUBLIC
STREETLIGHT |
|  | ESB SUBSTATION & ASSOCIATED
OFF-LOADING SWITCHGEAR |
|  | REFER TO DRAWINGS NOTES |
|  | SITE LIGHTING MINI PILLAR |
|  | ESB POLE |

F	-	-
E	-	-
D	-	-
C	-	-
B	-	-
A	-	-
Revision Suffix	Revision details	Date
Client LIMEHILL ESKER LTD.		
Job title DUNLO SHD, BALLINASLOE, CO. GALWAY		
Drawing title PROPOSED SITE DUCTING SERVICES LAYOUT		
R. G. GREENE & ASSOCIATES <i>Consulting Engineers</i> <i>Civil, Environmental & Structural</i> Caher House, Loughrea, Galway, H62 FF61 Tel 087 2596296 Email ronnie@greene.ie 		
chkd. R.G.	date 18/08/2022	scale 1:1000 @ A1
drawn W.G.		rev -
Drawing No		2521 - 201